


Note: The zone alarm action programming must be selected to activate relay outputs 1 or 2 in order to activate the appropriate relay.

Architects and Engineers CAD Drawings		 Digital Monitoring Products 2841 E. Industrial, Springfield, MO 65802	
FILE NAME		TITLE	
DRAWN	DATE	XR5, 866 Wiring	
CHECKED	SCALE	PART NO.	REV.
APPR'VD	SHEET 1 OF 1		