

ALVY.S3598 - Access Control System Units

Access Control System Units

[See General Information for Access Control System Units](#)**DIGITAL MONITORING PRODUCTS INC**2500 N Partnership Blvd
Springfield, MO 65803-8877 USA

S3598

ANSI/UL 294 (6th Ed.) Access Control Performance Levels

Model(s)	Product Type(s)	Access Control Line Security	Destructive Attack	Endurance	Standby Power	Condition(s) and Note(s)
XR550, XR150, XR550FC, XR150FC, may be followed by any of the following -D (dialer), -E (encryption), and/or -N (network)	Access Control Units	I	I	IV	IV	—
270	Transient Suppressions	I	I	IV	IV	—
7060, 7060A, 7063, 7063A, 7070, 7070A, 7073, 7073A, 7160, 7163, 7170, 7173, 7560, 7560A, 7563, 7563A, 7570, 7570A, 7573, 7573A	LCD Keypads	I	I	IV	IV	For use with Access control units Models XR150, XR550, XR150FC, and XR550FC
352S, 342	Battery Enclosures	I	N/A	N/A	N/A	—
352P, 352X	Control panel enclosures	I	N/A	N/A	N/A	—
270	Digital Cellular Communicator	I	I	IV	IV	—

734, 734N	Weigand interface module	I	I	IV	I	Model 734N with enclosure can also be used as an accessory *Must be connected to UL 294 or UL 603 Power Supply with 4 hours battery back up.
734N-POE	Weigand interface module	I	I	IV	I	Intended to be installed in metal enclosure, see manual for details. *Must be connected to UL 294 or UL 603 Power Supply or UL 294 POE Injector with 4 hours battery back up.

Last Updated on 2019-03-18

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2021 UL LLC"