



All wiring for CellComSLCF applications must be in conduit and no more than 20 feet from the Fire Panel being monitored. See LT-1339 Install Guide.

| | | | |
|--|----------------------|---|--|
| Architects and Engineers CAD Drawings | |  Digital Monitoring Products 2841 E. Industrial, Springfield, MO 65802 | |
| FILE NAME | TITLE | | CellComSLC PCB PART NO. _____ REV. _____ |
| DRAWN LK | DATE 11/19/15 | | |
| CHECKED | SCALE NTS | | |
| APPR'VD | SHEET 1 OF 1 | | |