

# DualCom™ Programming Sheet

NAME \_\_\_\_\_ ACCOUNT NUMBER \_\_\_\_\_ DATE \_\_\_\_\_  
 ADDRESS \_\_\_\_\_ CITY \_\_\_\_\_ STATE \_\_\_\_\_ ZIP \_\_\_\_\_

 Factory default values are shown in **bold**.

## COMMUNICATION

Account Number    \_\_\_\_\_ (1 to 65,535, default = **12345**)  
 Transmission Delay    \_\_\_\_ (0, 15 to 45 sec., default = **0**)  
 Communication Type   NET WIFI CELL  
 Backup Cell           NO YES  
 Test Time             \_\_ : \_\_ AM PM  
 Net Test Days         \_\_ (0 to 60 days, default = **1**)  
 Cell Test Days        \_\_ (0 to 60 days, default = **1**)  
 Check-In Minutes     \_\_\_\_ (0, or 3 to 240 min., default = **0**)  
 Fail Time             \_\_\_\_ (0, or 3 to 240 min., default = **0**)  
 Backup Check-in Min   \_\_\_\_ (0, or 3 to 240 min., default = **0**)  
 Backup Fail Time     \_\_\_\_ (0, or 3 to 240 min., default = **240**)

### Receiver 1 Programming:

Alarm Reports        NO     **YES**  
 Supv/Trouble Reports   NO     **YES**  
 O/C & User Reports   NO     **YES**  
 Test Reports         NO     **YES**  
 First IP Address     \_\_\_\_.\_\_\_\_.\_\_\_\_.\_\_\_\_  
 First IP Port        \_\_\_\_ (default = **2001**)  
 Second IP Address    \_\_\_\_.\_\_\_\_.\_\_\_\_.\_\_\_\_  
 Second IP Port       \_\_\_\_ (default = **2001**)

### Receiver 2 Programming:

Alarm Reports        **NO**    YES  
 Receiver 2 Backup?   **NO**    YES  
 Supv/Trouble Reports   **NO**    YES  
 O/C & User Reports   **NO**    YES  
 Test Reports         **NO**    YES  
 First IP Address     \_\_\_\_.\_\_\_\_.\_\_\_\_.\_\_\_\_  
 First IP Port        \_\_\_\_ (default = **2001**)  
 Second IP Address    \_\_\_\_.\_\_\_\_.\_\_\_\_.\_\_\_\_  
 Second IP Port       \_\_\_\_ (default = **2001**)

## NETWORK OPTIONS

WPS                   NO     **YES**  
 SSID                  \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 Wireless Security    WEP **WPA** NONE  
 Wireless Key         \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 DHCP                 NO     **YES**  
 Local IP Address     \_\_\_\_.\_\_\_\_.\_\_\_\_.\_\_\_\_  
 Gateway Address     \_\_\_\_.\_\_\_\_.\_\_\_\_.\_\_\_\_  
 Subnet Mask         \_\_\_\_.\_\_\_\_.\_\_\_\_.\_\_\_\_  
 DNS Server           \_\_\_\_.\_\_\_\_.\_\_\_\_.\_\_\_\_  
 Programming Port    \_\_\_\_ (default = **2001**)

## REMOTE OPTIONS

Remote Key           \_\_\_\_\_  
 Disarm               NO     **YES**  
 App Key              \_\_\_\_\_

## SYSTEM REPORTS

Opening/Closing Reports   NO     **YES**  
 Zone Restoral Reports    NO     **YES**     DISARM  
 Send Stored Messages    **NO**    YES

## SYSTEM OPTIONS

Entry Delay 1         \_\_\_\_ (30 to 250 sec., default = **30**)  
 Exit Delay            \_\_\_\_ (45 to 250 sec., default = **60**)  
 Cross Zone Time      \_\_\_\_ (0, 4 to 250 sec., default = **0**)  
 Power Fail Delay     \_\_\_\_ (0, 1 to 9 hrs., default = **1**)  
 Swinger Bypass Trips   \_\_\_\_ (0 to 6, default = **2**)  
 Reset Swinger Bypass   **NO**    YES  
 Time Changes         NO     **YES**  
 Hours from GMT        \_\_\_\_ (0 to 23 hrs., default = **6**)  
 Keypad Input          **NONE**   ECP    DSC  
 ECP Partition Number   \_\_\_\_ (1 to 8, default = **1**)  
 CID Format             **DMP**   CID    4-2    SIA

## OUTPUT OPTIONS

Cutoff Outputs        1     2  
 Cutoff Time          \_\_\_\_ (0 to 15min., default = 0)  
 Comm Fail Output     \_\_\_\_ (0 to 2, F1-20, default = 0)  
 Armed Output         \_\_\_\_ (0 to 2, F1-20, default = 0)  
 Remote Arming Output   \_\_\_\_ (0 to 2, F1-20, default = 0)  
 Heat Saver Temperature   \_\_\_\_ (0, 55 to 95 degrees, default = 0)  
 Cool Saver Temperature   \_\_\_\_ (0, 55 to 95 degrees, default = 0)

## AREA INFORMATION

### Area 1

Area Name            \_\_\_\_\_  
 Auto Arming          **NO** YES  
 Bad Zones            **BYP** FORC REF (When using Schedules)  
 Auto Disarming       **NO** YES

### Area 2

Area Name            \_\_\_\_\_  
 Auto Arming          **NO** YES  
 Bad Zones            **BYP** FORC REF  
 Auto Disarming       **NO** YES

### Area 3

Area Name            \_\_\_\_\_  
 Auto Arming          **NO** YES  
 Bad Zones            **BYP** FORC REF  
 Auto Disarming       **NO** YES

### Area 4

Area Name            \_\_\_\_\_  
 Auto Arming          **NO** YES  
 Bad Zones            **BYP** FORC REF  
 Auto Disarming       **NO** YES

### Area 5

Area Name            \_\_\_\_\_  
 Auto Arming          **NO** YES  
 Bad Zones            **BYP** FORC REF  
 Auto Disarming       **NO** YES

### Area 6

Area Name            \_\_\_\_\_  
 Auto Arming          **NO** YES  
 Bad Zones            **BYP** FORC REF  
 Auto Disarming       **NO** YES

# DualCom™ Programming Sheet

Zone Information	Type	Area	Disarmed Open			Disarmed Short			Armed Open			Armed Short			Swinger	Cross Zone	Receiver Routing	Style
			Message	Output*	Action	Message	Output*	Action	Message	Output*	Action	Message	Output*	Action				
			A T L -	0 S P M F	- S A	- 0 S P M F	0 S A	0 S A	0 S A	0 S A	0 S A	0 S N or Y	0 S N or Y	0 S N or Y				
Assign Area and Disarmed condition for NT, DY, EX, A1, and A2 only. Assign Style for AR only. Zone Type Defaults	-- DY FI EM A1 FV		1 to 6													NORM 1 2 BOTH	TGL ARM DIS STEP MNT	
NIGHT	NT			-	0	S	-	0	S	A	0	S	A	0	S	Y	N	
DAY	DY			T	0	S	T	0	S	A	0	S	A	0	S	Y	N	
EXIT	EX			-	0	S	-	0	S	A	0	S	A	0	S	Y	N	
FIRE	FI									T	0	S	A	0	S	N	N	
PANIC	PN									T	0	S	A	0	S	N	N	
EMERGENCY	EM									T	0	S	A	0	S	N	N	
SUPERVISORY	SV									T	0	S	A	0	S	N	N	
AUXILIARY 1	A1			T	0	S	A	0	S	T	0	S	A	0	S	N	N	NORM
AUXILIARY 2	A2			T	0	S	A	0	S	T	0	S	A	0	S	N	N	NORM
FIRE VERIFY	FV									T	0	S	A	0	S	N	N	
ARMING	AR																	TGL
Zone #	Zone Name	Serial Number	* Outputs = 31 to 34, 41 to 44, or F1-F20. Not available for this zone type.															



Designed, engineered, and manufactured in Springfield, MO using U.S. and global components.  
**LT-1860 21203**  
 © 2023

**INTRUSION • FIRE • ACCESS • NETWORKS**  
 2500 North Partnership Boulevard  
 Springfield, Missouri 65803-8877  
 800.641.4282 | DMP.com