# Remote Link™



## FEATURE UPDATE | JUNE 2018

## Version 1.85 Update

Effective June 18, 2018, all Remote Link<sup>™</sup> software will be updated to Version 1.85 (6/14/18). If your current Remote Link software is previous to Version 1.46, update to Version 1.59 (available at DMP.com/Dealer\_Direct) before updating to Version 1.85 (6/14/18).

### Features

#### Panel Version 181 Support

Remote Link Version 1.85 (6/14/18) now supports panel Version 181 for XR150/XR550 Series panels and XT30/XT50, XTLplus<sup>™</sup>, and XTLplus-GW Series panels.

#### **Open/Close Reports**

For XR150/XR550 Series panels, you can now configure Opening/Closing Reports for individual areas, rather than using this report type as a global setting for all areas. This new functionality allows you to control which areas can send opening and closing reports to the central station when an area is disarmed or armed.

#### Panic Lockdown

With Remote Link Version 1.85 (6/14/18), you can now program Panic type zones to trigger a Lockdown, allowing you to quickly put the system in a Lockdown state using a panic button. If the panic type zones aren't programmed to trigger a Lockdown, it will only send a panic when they are triggered. Use the directions below to program a panic zone with the Lockdown functionality:

- 1. In Remote Link, select an **Account**.
- 2. Navigate to **Zone Information** and create a new panic zone or edit an existing panic zone.
- 3. Click the **Advanced** tab.
- 4. Click the **Lockdown** box to allow this panic zone to trigger a Lockdown when it's activated.
- 5. Click **OK** to save the information.

#### Lockdown Override

Prior to Remote Link Version 1.85, the only way to exit a Lockdown was to manually unlock each door using Remote Link, VirtualKeypad.com, or an associated keypad.

When updating to Version 1.85, a new profile option is available called Lockdown Override. Any user who has **Lockdown Override** and **Sensor Reset** enabled in their profile will have the ability to return the Lockdown system back to its previous state. Users with their profile programmed this way can simply perform a Sensor Reset using Remote Link or an associated keypad to remove the system from its Lockdown state.

## **Obtaining the New Software**

The Remote Link Version 1.85 (6/14/18) software update is available for download, free of charge, on the DMP Dealer Direct website at DMP.com/Dealer\_Direct.