



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING & INVESTIGATIONS DIVISION  
BUILDING MATERIALS LISTING PROGRAM**

**LISTING SERVICE**

<b>LISTING No.:</b>	7315-1157:0114
<b>CATEGORY:</b>	7315 - POWER UNITS
<b>LISTEE:</b>	Digital Monitoring Products, Inc. 2500 N. Partnership Blvd, Springfield, MO, 65803 Contact: Wilson, James 417-447-9697 Email: jwilson@dmp.com
<b>DESIGN:</b>	Models 505-12, *505-12A, *505-12L, 505-12LX, *505-12LXL, *505-12LXA, 504-24, 504-24LX power supplies/battery chargers. Refer to listee's data sheet for additional detailed product description and operational considerations.
<b>RATING:</b>	12 or 24 VDC
<b>INSTALLATION:</b>	In accordance with listee's printed installation, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.
<b>MARKING:</b>	Listee's name, model number, electrical rating, and UL label.
<b>APPROVAL:</b>	Listed as power supplies/battery chargers to provide auxiliary power for fire alarm and access control systems. Refer to listee's Installation Instruction Manual for details.
<b>NOTES:</b>	

\*Rev. 06-24-2005



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

**Date Issued: 05/30/2024**

**Listing Expires: 06/30/2025**

Authorized By: **David Castillo**, Program Coordinator  
Fire Engineering & Investigations Division