



45 YEARS  
1975-2020

## STATEMENT OF COMPLIANCE

May 18, 2021

The DMP XR500E/XR550E Control Panel system meets the applicable control panel sections shown below:

- ICD 705 Chapter 8 section A (2) b)
- ICD 705 Chapter 8 section C (3) AES certificate #2350 (128-bit) #2595 (256-bit)
- NISPOM 5-313 Automated Access Control Systems Section a) Items 1 and 2
  - (1) The chances of an unauthorized individual gaining access through normal operation of the equipment are less than one in ten thousand.
  - (2) The chances of an authorized individual being rejected for access through normal operation of the equipment are less than one in one thousand.
- NISPOM 5-313 Automated Access Control Systems Section b) Item 1
  - DMP access control credentials use a proximity activated circuit which stores a site (facility) code and individual user code.
- NISPOM 5-313 Automated Access Control Systems Section d)
  - Each time an access control credential is scanned the user code is validated against the database of user codes stored in the control panel.

Best Regards,

A handwritten signature in black ink, appearing to read 'B. Tucker', written in a cursive style.

Brad Tucker  
VP, Product Management & Support  
Digital Monitoring Products, Inc.

