

## TECHNICAL UPDATE | JUNE 2025

### Version 102 Update

Updated Version 102 (4/9/25) firmware is now available for 7830F Graphic Remote Annunciators.

#### Keypad Status List Messages

Previously, Alarm, Trouble, and Supervisory messages did not immediately clear in the status list at the keypad after resetting the panel. Now, messages are immediately cleared after performing a reset.

To ensure keypad status list messages clear immediately after a reset, update 7830F Graphic Remote Annunciators to firmware Version 102 (4/9/25) and [XF6 Series Fire Control Panels to firmware Version 252 \(6/24/25\)](#).

### Obtaining the New Firmware

7830F Graphic Remote Annunciator firmware updates are available, free of charge, from DMP's [Product Software Downloads](#) page.