

TECHNICAL UPDATE | JULY 2025

Version 252 Update

Updated Version 252 (7/15/25) firmware is now available for XR Series Control Panels.

Bell Circuit

This update improves bell circuit monitoring to confirm the panel bell is only active during alarm conditions.

Exit Delay Restart

Previously, the **Exit Delay** restart feature was enabled when **Occupied Premises** was set to **YES** and disabled when **Occupied Premises** was set to **NO**. Now, **Exit Delay** restart is always enabled.

Chime Improvement

This update improves the panel chime to properly sound when triggered.

Z-Wave Improvement

Previously, Z-Wave device features had slower response times between 4-6 a.m. Now, Z-Wave device features properly respond during these hours.

Obtaining the New Firmware

XR Series firmware updates are available, free of charge, on Dealer Admin (dealer.securecomwireless.com) or for download from DMP's [Product Software Downloads](#).