

## 1135 Wireless Siren

March 2011

### Hardware Update

Effective February 21, 2011, all 1135 Wireless Sirens are being manufactured with Level G hardware. This is an update from Level E shipped previously.

### Updated Hardware

#### Wireless Siren

The 1135 has been enhanced by a filter addition to improve two way communication with the control panel when the siren is to be turned off.

Previously, some 1135 Wireless Sirens could not receive the siren off command from the panel especially if they were located far from the panel. This was because electrical noise from the running siren caused a reduction in wireless communication capabilities. The previous Level E update improved this operation, however, Level G extends the distance even further.

Note: The internal fail safe operation of the 1135 siren circuit will always automatically turn off the siren after 15 minutes.

If an installed 1135 Wireless Siren cannot be immediately turned off by the control panel, it may be moved closer to improve communication. If this fails to remedy the situation, then the 1135 could be returned to DMP for update to Level G.

### Receiving the New Hardware

To update to level G, return any 1135 PCB to DMP and simply indicate "Update to Latest Hardware Level" on the 5-digit RMA tag. The update will be done as a Warranty Repair at no charge, regardless of when the 1135 was purchased. If a wireless siren is returned for other repair needs, this update will be automatically performed as standard repair procedure. If you need RMA tags, contact DMP Customer Service at 1-800-641-4282.

