

Level 103 Hardware Update

Effective January 12, 2022, all 263LTE-V-X1 Cellular Communicators are being manufactured with Level 103 hardware. X1 Series Controllers must be updated to Version 214 (12/21/2021) in order to use 263LTE-V-X1 communicators with Level 103 hardware.

More Information

To learn more about manually or automatically updating your X1 Controller, see [Update an X1 Controller](#).